

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3550-1459:112 Page 1 of 1

CATEGORY: Door Closer/Holders/Releasing Devices

LISTEE: Sentrol, Inc., 1510 Tate Blvd., S.E., Hickory, NC 28602
Contact: Gene Hukkanen (503) 691-7369

DESIGN: Models DHF, DHR, DHS, DHFM1* and DHFM2* door holders. Unit may have additional suffixes 1224 (12 VAC, 24 VAC), 24120 (24 VAC, 120 VAC) or 24220 (24 VAC, 240 VAC) to signify the dual coil electrical ratings of each device. These door holders consist of electromagnetic assemblies housed in either listed outlet boxes or secured within aluminum or zinc cover plates. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. The units are intended to be flush, recessed or surface mounted to the adjacent wall surface.

MARKING: Listee's name, model number, electrical rating, load rating, and UL label.

APPROVAL: Listed as door holders for use on swinging type fire doors where permitted per codes. For indoor use only.

NOTE: Formerly 3550-0447:136

02-03-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager